

**Information requirements
(air-to-air air conditioners)**

| Model(s):GUD125ZD/A-T、 GUD125W/NhA-T | | | | | | | |
|---|--------------------------------------|---------------|---|--|--------------|--------|---------|
| Outdoor side heat exchanger of air conditioner | air | | | | | | |
| Indoor side heat exchanger of air conditioner | air | | | | | | |
| Type | compressor driven vapour compression | | | | | | |
| If applicable: driver of compressor | electric motor | | | | | | |
| Item | Symbol | Value | Unit | Item | Symbol | Value | Unit |
| Rated cooling capacity | $P_{rated,c}$ | 12,1 | kW | Seasonal space cooling energy efficiency | $\eta_{s,c}$ | 240,7 | % |
| Declared cooling capacity for part load at given outdoor temperatures T_j and indoor 27°/19 °C (dry/wet bulb) | | | | Declared energy efficiency ratio or gas utilisation efficiency/auxiliary energy factor for part load at given outdoor temperatures T_j | | | |
| $T_j = + 35\text{ °C}$ | P_{dc} | 12,21 | kW | $T_j = + 35\text{ °C}$ | EER_d | 3,11 | - |
| $T_j = + 30\text{ °C}$ | P_{dc} | 8,59 | kW | $T_j = + 30\text{ °C}$ | EER_d | 4,46 | - |
| $T_j = + 25\text{ °C}$ | P_{dc} | 5,53 | kW | $T_j = + 25\text{ °C}$ | EER_d | 7,02 | - |
| $T_j = + 20\text{ °C}$ | P_{dc} | 3,92 | kW | $T_j = + 20\text{ °C}$ | EER_d | 10,50 | - |
| Degradation co-efficient for air conditioners(*) | C_{dc} | 0,25 | — | | | | - |
| Power consumption in modes other than 'active mode' | | | | | | | |
| Off mode | P_{OFF} | 0,0017 | kW | Crankcase heater mode | P_{CK} | 0.0000 | kW |
| Thermostat-off mode | P_{TO} | 0,0102 | kW | Standby mode | P_{SB} | 0,0017 | kW |
| Other items | | | | | | | |
| Capacity control | variable | | | For air-to-air air conditioner: air flow rate, outdoor measured | — | 5900 | m^3/h |
| Sound power level, indoor/outdoor | L_{WA} | 61.2/ 69.7 | dB | | | | |
| If engine driven: Emissions of nitrogen oxides | $NO_x(**)$ | / | mg/kWh fuel input GCV | | | | |
| GWP of the refrigerant | 675 | | kg CO ₂ eq (100 years) | | | | |
| Contact details: West Jinji Rd, Qianshan, Zhuhai, Guangdong, China, 519070 | | | | Name of manufacturer: GREE ELECTRIC APPLIANCES,INC. OF ZHUHAI | | | |
| (*) If C_{dc} is not determined by measurement then the default degradation coefficient air conditioners shall be 0,25. (**) From 26 September 2018. Where information relates to multi-split air conditioners, the test result and performance data may be obtained on the basis of the performance of the outdoor unit, with a combination of indoor unit(s) recommended by the manufacturer or importer. | | | | | | | |

**Information requirements
(heat pump)**

| | | | | | | | |
|--|---------------------------|---------------|-----------------------|---|--------------|--------|---------|
| Model(s):GUD125ZD/A-T、GUD125W/NhA-T | | | | | | | |
| Outdoor side heat exchanger of heat pump | air | | | | | | |
| Indoor side heat exchanger of heat pump | air | | | | | | |
| Indication if the heater is equipped with a supplementary heater | no | | | | | | |
| If applicable: driver of compressor | electric motor | | | | | | |
| Parameters declared for | Average climate condition | | | | | | |
| Item | symbol | value | unit | Item | symbol | value | unit |
| Rated heating capacity | $P_{rated,h}$ | 13,5 | kW | Seasonal space heating energy efficiency | $\eta_{s,h}$ | 151,9 | % |
| Declared heating capacity for part load at indoor temperature 20 °C and outdoor temperature T_j | | | | Declared coefficient of performance or gas utilisation efficiency/auxiliary energy factor for part load at given outdoor temperatures T_j | | | |
| $T_j = -7\text{ °C}$ | P_{dh} | 9,10 | kW | $T_j = -7\text{ °C}$ | COP_d | 2,49 | - |
| $T_j = +2\text{ °C}$ | P_{dh} | 5,52 | kW | $T_j = +2\text{ °C}$ | COP_d | 3,77 | - |
| $T_j = +7\text{ °C}$ | P_{dh} | 3,67 | kW | $T_j = +7\text{ °C}$ | COP_d | 5,04 | - |
| $T_j = +12\text{ °C}$ | P_{dh} | 2,95 | kW | $T_j = +12\text{ °C}$ | COP_d | 6,11 | - |
| T_{biv} = bivalent temperature | P_{dh} | 9,10 | kW | T_{biv} = bivalent temperature | COP_d | 2,49 | - |
| T_{OL} = operation limit | P_{dh} | 9,68 | kW | T_{OL} = operation limit | COP_d | 2,50 | - |
| For air-to-water heat pumps: $T_j = -15\text{ °C}$ (if $TOL < -20\text{ °C}$) | P_{dh} | NA | kW | For water-to-air heat pumps: $T_j = -15\text{ °C}$ (if $TOL < -20\text{ °C}$) | COP_d | NA | - |
| Bivalent temperature | T_{biv} | -7.00 | °C | For water-to-air heat pumps: Operation limit temperature | T_{ol} | -10.00 | °C |
| Degradation co-efficient heat pumps(**) | C_{dh} | 0,25 | — | | | | |
| Power consumption in modes other than 'active mode' | | | | Supplementary heater | | | |
| Off mode | P_{OFF} | 0,0017 | kW | Back-up heating capacity (*) | elbu | - | kW |
| Thermostat-off mode | P_{TO} | 0,0140 | kW | Type of energy input | | | |
| Crankcase heater mode | P_{CK} | 0,0000 | kW | Standby mode | P_{SB} | 0,0017 | kW |
| Other items | | | | | | | |
| Capacity control | variable | | | For air-to-air heat pumps: air flow rate, outdoor measured | — | 5900 | m^3/h |
| Sound power level, indoor/outdoor measured | L_{WA} | 60.9/ 68.6 | dB | | | | |
| Emissions of nitrogen oxides (if applicable) | NO_x (**) | / | mg/kW h input GCV | For water/brine-to-air heat pumps: Rated brine or water flow rate, outdoor side heat exchanger | — | — | m^3/h |
| GWP of the refrigerant | 675 | | kg CO2 eq (100 years) | | | | |
| Contact details: West Jinji Rd, Qianshan, Zhuhai, Guangdong, China, 519070 | | | | Name of manufacturer: GREE ELECTRIC APPLIANCES,INC. OF ZHUHAI | | | |
| (*) | | | | | | | |
| (**) If C_{dh} is not determined by measurement then the default degradation coefficient of heat pumps shall be 0,25. | | | | | | | |
| (***) From 26 September 2018. | | | | | | | |
| Where information relates to multi-split heat pumps, the test result and performance data may be obtained on the basis of the performance of the outdoor unit, with a combination of indoor unit(s) recommended by the manufacturer or importer. | | | | | | | |