

**Information requirements
(air-to-air air conditioners)**

Model(s):GUD140PHS/A-T、GUD140W/NhA-T							
Outdoor side heat exchanger of air conditioner	air						
Indoor side heat exchanger of air conditioner	air						
Type	compressor driven vapour compression						
If applicable: driver of compressor	electric motor						
Item	Symbol	Value	Unit	Item	Symbol	Value	Unit
Rated cooling capacity	$P_{rated,c}$	13.4	kW	Seasonal space cooling energy efficiency	$\eta_{s,c}$	241.2	%
Declared cooling capacity for part load at given outdoor temperatures T_j and indoor 27°/19 °C (dry/wet bulb)				Declared energy efficiency ratio or gas utilisation efficiency/auxiliary energy factor for part load at given outdoor temperatures T_j			
$T_j = + 35\text{ °C}$	P_{dc}	13.40	kW	$T_j = + 35\text{ °C}$	EER_d	2.94	-
$T_j = + 30\text{ °C}$	P_{dc}	9.59	kW	$T_j = + 30\text{ °C}$	EER_d	4.43	-
$T_j = + 25\text{ °C}$	P_{dc}	6.27	kW	$T_j = + 25\text{ °C}$	EER_d	6.91	-
$T_j = + 20\text{ °C}$	P_{dc}	3.19	kW	$T_j = + 20\text{ °C}$	EER_d	10.87	-
Degradation co-efficient for air conditioners(*)	C_{dc}	0.25	—				-
Power consumption in modes other than 'active mode'							
Off mode	P_{OFF}	0.0020	kW	Crankcase heater mode	P_{CK}	0	kW
Thermostat-off mode	P_{TO}	0.0126	kW	Standby mode	P_{SB}	0.0020	kW
Other items							
Capacity control	variable			For air-to-air air conditioner: air flow rate, outdoor measured	—	5900	m^3/h
Sound power level, indoor /outdoor	L_{WA}	68/70	dB				
If engine driven: Emissions of nitrogen oxides	$NO_x(**)$	/	mg/kWh fuel input GCV				
GWP of the refrigerant	675		kg CO ₂ eq (100 years)				
Contact details: West Jinji Rd, Qianshan, Zhuhai, Guangdong, China, 519070				Name of manufacturer: GREE ELECTRIC APPLIANCES,INC. OF ZHUHAI			
(*) If C_{dc} is not determined by measurement then the default degradation coefficient air conditioners shall be 0,25. (**) From 26 September 2018. Where information relates to multi-split air conditioners, the test result and performance data may be obtained on the basis of the performance of the outdoor unit, with a combination of indoor unit(s) recommended by the manufacturer or importer.							

**Information requirements
(heat pump)**

Model(s):GUD140PHS/A-T、GUD140W/NhA-T							
Outdoor side heat exchanger of	air						
Indoor side heat exchanger of heat	air						
Indication if the heater is equipped with a supplementary heater	no						
If applicable: driver of compressor	electric motor						
Parameters declared for	Average climate condition						
Item	symbol	value	unit	Item	symbol	value	unit
Rated heating capacity	$P_{rated,h}$	15.5	kW	Seasonal space heating energy efficiency	$\eta_{s,h}$	141.0	%
Declared heating capacity for part load at indoor temperature 20 °C and outdoor temperature T_j				Declared coefficient of performance or gas utilisation efficiency/auxiliary energy factor for part load at given outdoor temperatures T_j			
$T_j = -7\text{ °C}$	P_{dh}	10.45	kW	$T_j = -7\text{ °C}$	COP_d	2.55	-
$T_j = +2\text{ °C}$	P_{dh}	6.32	kW	$T_j = +2\text{ °C}$	COP_d	3.35	-
$T_j = +7\text{ °C}$	P_{dh}	4.11	kW	$T_j = +7\text{ °C}$	COP_d	4.73	-
$T_j = +12\text{ °C}$	P_{dh}	2.88	kW	$T_j = +12\text{ °C}$	COP_d	6.08	-
T_{biv} = bivalent temperature	P_{dh}	10.45	kW	T_{biv} = bivalent temperature	COP_d	2.55	-
T_{OL} = operation limit	P_{dh}	9.92	kW	T_{OL} = operation limit	COP_d	2.51	-
For air-to-water heat pumps: $T_j = -15\text{ °C}$ (if $TOL < -20\text{ °C}$)	P_{dh}	-	kW	For water-to-air heat pumps: $T_j = -15\text{ °C}$ (if $TOL < -20\text{ °C}$)	COP_d	-	-
Bivalent temperature	T_{biv}	-7.00	°C	For water-to-air heat pumps: Operation limit temperature	T_{ol}	-	°C
Degradation co-efficient heat pumps(**)	C_{dh}	0.25	—				
Power consumption in modes other than 'active mode'				Supplementary heater			
Off mode	P_{OFF}	0.0020	kW	Back-up heating capacity (*)	e_{lbu}	-	kW
Thermostat-off mode	P_{TO}	0.0139	kW	Type of energy input	-		
Crankcase heater mode	P_{CK}	0	kW	Standby mode	P_{SB}	0.0020	kW
Other items							
Capacity control	variable			For air-to-air heat pumps: air flow rate, outdoor measured	—	5900	m^3/h
Sound power level, indoor/outdoor measured	L_{WA}	68/72	dB				
Emissions of nitrogen oxides (if applicable)	$NO_x(***)$	-	mg/kWh input GCV	For water/brine-to-air heat pumps: Rated brine or water flow rate, outdoor side heat exchanger	—	-	m^3/h
GWP of the refrigerant	675		kg CO ₂ eq (100 years)				
Contact details: West Jinji Rd, Qianshan, Zhuhai, Guangdong, China, 519070				Name of manufacturer: GREE ELECTRIC APPLIANCES,INC. OF ZHUHAI			

(*)

(**) If C_{dh} is not determined by measurement then the default degradation coefficient of heat pumps shall be 0,25.

(***) From 26 September 2018.

Where information relates to multi-split heat pumps, the test result and performance data may be obtained on the basis of the performance of the outdoor unit, with a combination of indoor unit(s) recommended by the manufacturer or importer.