



Test Report No.:	NT	NTRE20170425 Page 1 of 17					
Applicant Name:		Gree Electric Appliances Inc. of Zhuhai  Jinji West Road, Qianshan, Zhuhai, Guangdong 519070, P.R.China					
Test item:	Split	t Heat Pump Air	Condi	tioner			
Identification:	GUI	D140W/NhA-T+	GUD1	40PHS/A-T	Serial No.:	Engineering sample	
Receipt No.:	RZ0	0340214			Date of receipt:	2018.1.10	
Testing location: Gree Electric Appliances Inc. of Zhuhai Jinji West Road, Qianshan, Zhuhai, Guangdong 519070, P.R.China			R.China				
Test specification: COMMISSION REGULATION (EU) 2016/2281 EN 14825:2016 EN 14511-2,3:2013 EN 12102:2013							
Test Result: The test items passed the test specification(s).							
Testing Laboratory:	Test	ting Center of G	ree Ele	ectric Applianc	es Inc. of Zhuhai		
tested by:			reviewed by:				
2018-3-15	MaJiedan		2018-3-15 LuZhibin				
Date	Name/Position	Signature		Date	Name/Position	Signature	+

Other Aspects:

Abbreviations: P(ass) = passed

F(ail) = failed

N/A = not applicable N/T =not tested

This test report relates to the a. m. test sample. Without permission of the test center this test report is not permitted to be duplicated in extracts. This test report does not entitle to carry any safety mark on this or similar products.

TRF No.: EN 14511 & EN 14825

Report NO.: *NTRE20170425* Page 2 of 10



(EU) 2016/2281 and EN 14511 & EN 14825				
Clause	Requirement - Test	Result - Remark	Verdict	

#### **Summary of testing**

- 1. The appliance was tested according to EN 14511.
- 2. The SEER、  $\eta_{\,s,c}$  and SCOP、  $\eta_{\,s,h}$  were calculated according to EN14825.
- 3. All the tests were performed on the outdoor model GUD140W/NhA-T and the indoor model GUD140PHS/A-T as representive.
- 4. The samples are engineering samples without serial numbers.

Test item particulars	
Class of temperature	T1
Type:	Split Heat Pump Air Conditioner
Degree of protection	Indoor unit:IPX0 Outdoor unit:IPX4
Supply Connection	Type Y attachment
Possible test case verdicts:	
- test case does not apply to the test object:	N/A
- test object does meet the requirement:	P(Pass)
- test object does not meet the requirement:	F(Fail)
Testing	
Date of receipt of test item:	2018.2.23
Date (s) of performance of tests:	2018.2.24-2018.3.1

### **General remarks**

- This appliance is heat pump type air conditioner, which consist of one outdoor unit and one indoor units.
- >The indoor units are ducted type air conditioners, which are usually not accessible (only for maintenance purpose).
- ➤ Cooling and heating modes are applied by reverse cycle method. In the heating mode, defrost operation may be applied.
- >The indoor unit is equipped with an infrared wireless battery powered remote control unit.

#### **Critical components:**

Model	Compressor model	Indoor fan motor	Outdoor fan motor
GUD140W/NhA-T+ GUD140PHS/A-T	QXFS-F428zX450E	FG250A-ZL	B-SWZ150A(ZWF- 150A)

Report NO.: *NTRE20170425* Page 3 of 10



(EU) 2016/2281 and EN 14511 & EN 14825				
Clause	Requirement - Test	Result - Remark	Verdict	

### Rating labels and marking:

### Match table:

Indoor unit	Outdoor unit
GUD140PHS/A-T	GUD140W/NhA-T

The artwork below may be only a draft.

# GREE AIR CONDITIONER OUTDOOR UNIT

Model	(	GUD140W/NhA-T	
Rated Voltage Rated Frequency	220-240V~50Hz 208-230V~60Hz	Refrigerant R32	A
Climate Type	T1	Refri. Charge	
Weight	95kg	2.8kg	- 54
Rated Current	25.0A	GWP	675
Moisture Protection	IPX4	CO2 Equivalent	1.89t
Operating Press	ure ( Discharge	Side/Suction Side)	4.6/2.5MPa
Maximum Allowable Pressure			4.6MPa
Manufactured Date			

Contains fluorinated greenhouse gases

GREE ELECTRIC APPLIANCES, INC. OF ZHUHAI







## **G**GREE

### DUCTED TYPE AIR CONDITIONER

Model GUD140PHS/A-T Rated Voltage/Frequency 220-240V~/50Hz

208~230V~/60Hz

Cooling Capacity 13400W
Heating Capacity 15500W
Rated Input 195W
Air Flow Volume 2200m³/h
Sound Pressure Level 43dB(A)
Weight 50kg

Manufactured Date

GREE ELECTRIC APPLIANCES, INC. OF ZHUHAI





Add: West Jinji Rd, Qianshan, Zhuhai, Guangdong, China, 519070

Report NO.: NTRE20170425 Page 4 of 10



	(EU) 2016/2281 and EN 14511 & EN 14825				
Clause	Requirement - Test	Result - Remark	Verdict		

1	Seasonal space heating energy efficiency of air hea	ting products	
(a)	From 1 January 2018, the seasonal space heating energy efficiency of air heating products shall not fall below the values in Table 1	Measured η <sub>s,h</sub> :141.0% Measured η <sub>s,h</sub> ≥133%	Р
	For multi-split heat pumps, the manufacturer shall establish conformity with this regulation based on measurements and calculations according to Annex III.		N/A
	For each model of outdoor side unit, a list of recommended combinations with compatible indoor side units shall be included in the technical documentation.		N/A
	The declaration of conformity shall then apply to all combinations mentioned in this list.		N/A
	The list of recommended combinations shall be made available prior to the purchase/lease/hire of an outdoor side unit.		N/A
(b)	From 1 January 2021, the seasonal space heating energy efficiency of air heating products shall not fall below the values in Table 2	Measured η <sub>s,h</sub> :141.0% Measured η <sub>s,h</sub> ≥137%	Р
	For multi-split heat pumps the manufacturer shall establish conformity with this regulation based on measurements and calculations according to Annex III.		N/A
	For each model of outdoor side unit, a list of recommended combinations with compatible indoor side units shall be included in the technical documentation.		N/A
	The declaration of conformity shall then apply to all combinations mentioned in this list.		N/A
	The list of recommended combinations shall be made available prior to the purchase/lease/hire of an outdoor side unit.		N/A
2	Seasonal space cooling energy efficiency of cooling	products	
(a)	From 1 January 2018, the seasonal space cooling energy efficiency of cooling products shall not fall below the values in Table 3	Measured η <sub>s,c</sub> :241.2% Measured η <sub>s,c</sub> ≥181%	Р

Report NO.: *NTRE20170425* Page 5 of 10



	(EU) 2016/2281 and EN 14511 &	EN 14825	
Clause	Requirement - Test	Result - Remark	Verdict
	For multi-split air conditioners the manufacturer shall establish conformity with this regulation based on measurements and calculations according to Annex III.		N/A
	For each model of outdoor side unit, a list of recommended combinations with compatible indoor side units shall be included in the technical documentation.		N/A
	The declaration of conformity shall then apply to all combinations mentioned in this list.		N/A
	The list of recommended combinations shall be made available prior to the purchase/lease/hire of an outdoor side unit.		N/A
(b)	From 1 January 2021, the seasonal space cooling energy efficiency of cooling products shall not fall below the values in Table 4	Measured η <sub>s,c</sub> :241.2% Measured η <sub>s,c</sub> ≥189%	Р
	For multi-split air conditioners the manufacturer shall establish conformity with this regulation based on measurements and calculations according to Annex III.		N/A
	For each model of outdoor side unit, a list of recommended combinations with compatible indoor side units shall be included in the technical documentation.		N/A
	The declaration of conformity shall then apply to all combinations mentioned in this list.		N/A
	The list of recommended combinations shall be made available prior to the purchase/lease/hire of an outdoor side unit.		N/A
3	Seasonal energy performance ratio of high tempera	ature process chillers	
(a)	From 1 January 2018, the seasonal energy performance ratio of high temperature process chillers shall not fall below the values in Table 5		N/A
(b)	From 1 January 2021, the seasonal energy performance ratio of high temperature process chillers shall not fall below the values in Table 6		N/A
4	Emissions of nitrogen oxides		

Report NO.: NTRE20170425 Page 6 of 10



	(EU) 2016/2281 and EN 14511 & EN 14825				
Clause	Requirement - Test	Result - Remark	Verdict		
(a)	From 26 September 2018, the emissions of nitrogen oxides, expressed in nitrogen dioxide, of warm air heaters, heat pumps, comfort chillers and air conditioners shall not exceed values in Table 7		N/A		
(b)	From 1 January 2021, the emissions of nitrogen oxides, expressed in nitrogen dioxide, of warm air heaters shall not exceed values in Table 8		N/A		
5	Product information				
(a)	From 1 January 2018, the instruction manuals for installers and end-users, and free access websites of manufacturers, their authorised representatives and importers shall provide the following product information		Р		
(1)	for warm air heaters, the information set out in Table 9 of this Annex, measured and calculated in accordance with Annex III		N/A		
(2)	for comfort chillers, the information set out in Table 10 of this Annex, measured and calculated in accordance with Annex III		N/A		
(3)	for air-to-air air conditioners, the information set out in Table 11 of this Annex, measured and calculated in accordance with Annex III		Р		
(4)	for water/brine-to-air air conditioners, the information set out in Table 12 of this Annex, measured and calculated in accordance with Annex III		N/A		
(5)	for fan coil units, the information set out in Table 13 of this Annex, measured and calculated in accordance with Annex III		N/A		
(6)	for heat pumps, the information set out in Table 14 of this Annex, measured and calculated in accordance with Annex III		Р		
(7)	for high temperature process chillers, the information set out in Table 15 of this Annex, measured and calculated in accordance with Annex III		N/A		
(8)	any specific precautions that must be taken when the product is assembled, installed or maintained		N/A		

Report NO.: NTRE20170425 Page 7 of 10



	(EU) 2016/2281 and EN 14511 &	EN 14825	
Clause	Requirement - Test	Result - Remark	Verdict
(9)	for heat generators or cold generators designed for air heating or cooling products, and air heating or cooling product housings to be equipped with such heat or cold generators, their characteristics, the requirements for assembly, to ensure compliance with the ecodesign requirements for air heating or cooling products and, where appropriate, the list of combinations recommended by the manufacturer		Р
(10)	for multi-split heat pumps and multi-split air conditioners, a list of appropriate indoor units		N/A
(11)	for B1, C2 and C4 warm air heaters the following standard text: 'This warm air heater is intended to be connected only to a flue shared between multiple dwellings in existing buildings. Due to a lower efficiency, any other use of this warm air heater shall be avoided and would result in higher energy consumption and higher operating costs'		N/A
(b)	From 1 January 2018, the instruction manuals for installers and end-users, and a part for professionals of the free-access websites of manufacturers, their authorised representatives and importers shall provide the following product information		Р
(1)	information relevant for disassembly, recycling and/or disposal at end-of-life		Р
(c)	The technical documentation for the purposes of conformity assessment pursuant to Article 4 shall contain the following elements		Р
(1)	the elements specified in point (a)		Р
(2)	where the information relating to a specific model has been obtained by calculation on the basis of design, and/or extrapolation from other combinations, the technical documentation shall include details of such calculations and/or extrapolations, and of tests undertaken to verify the accuracy of the calculations undertaken, including details of the mathematical model for calculating performance of such combinations, and of measurements taken to verify this model, and a list of any other models where the information included in the technical documentation was obtained on the same basis		Р

Report NO.: NTRE20170425 Page 8 of 10



(EU) 2016/2281 and EN 14511 & EN 14825						
Clause	Requirement - Test	Result - Remark	Verdict			

# Test result of part load according to EN 14825: Calculation of SEER $_{\sim}$ $\eta_{s,c}$ in cooling mode:

Fu	ıll load (Pdesi	gnc):13400 W	Tdesignc: 35℃	Tested Voltage: 230V~	Frequenc	y: 50Hz			
Test item	Indoor DB/WB(℃)	Outdoor DB/WB(°	C) Tested Pc(W)	Tested <i>EER</i>	Cd	ESP(Pa)			
Α		35/-	13420.00	2.939	0,25	50			
В	27/19 30/-		9585.60	4.426	0,25	50			
С	21/19	25/-	6274.00	6.913	0,25	50			
D		20/-	3192.00	10.866	0,25	50			
		Psb=	Poff =2.020W; Pck=	0W; Pto=12.670W					
	Tested SEER 6.106								
	Tested r	<b>]</b> s,c		241.2%					
The c	The calculation method of SEER and η s,c according to the clause 6 of EN14825:2016.								

### Calculation of SCOP、 $\eta_{s,h}$ in heating mode:

Full load (Pdesignh):11700W Tdesignh: -10℃ Climate: Average									
Tbivalent: -7℃; TOL: -10℃ Tested Voltage: 230V~ Frequency: 50Hz									
Test item	Indoor DB(℃)	Outdoor DB/W	B(℃)	Tested Ph(W)	Tested	COP	Cd	ESP(Pa)	
Α		-7/-8		10452	2.54	6	0,25	50	
В		2/1 7/6		6318	3.34	3.347 0,25		50	
С	20/-			4111.5	4.728 0,25		0,25	50	
D	20/-	12/11		2881.1	6.08	6.081		50	
Е	TOL Tbivalent			9919.7	2.508		0,25	50	
F				10452	2.546		0.25	50	
Psb= Poff=2.02W; Pck= 0W; Pto=13.854W									
	Tested So	СОР			3.601				
	Tested i	η <sub>s,h</sub>	·		141.0%	%		·	
The calculation method of SCOP and η s,h according to the clause 7 of EN14825:2016.									

Report NO.: NTRE20170425 Page 9 of 10



(EU) 2016/2281 and EN 14511 & EN 14825						
Clause	Requirement - Test	Result - Remark	Verdict			

### Measured result summary

Outdoor side heat exchanger of air conditioner: air								
Indoor side heat exchanger of air conditioner: air								
Indication if the heater is equipped with a supplementary heater: no								
Type: compressor driven vapour compression								
If applicable: driver of compressor: electric motor								
Parameters shall be declared for the average heating season, parameters for the warmer and colder								
heating seasons are optional.								
Item	Symbol	Value	Unit		Item	Symbol	Value	Unit
Rated cooling capacity,outdoor	P <sub>rated,c</sub>	13.40	kW		Seasonal space cooling energy efficiency,outdoor	$\eta_{s,c}$	241.2	%
cooling capacity for part temperatures T <sub>j</sub> and indo	_				energy efficiency r outdoor temperat	•	load at g	given
T <sub>j</sub> = + 35 °C	P <sub>c</sub>	13.40	kW		T <sub>j</sub> = + 35 °C	EER	2.94	_
T <sub>j</sub> = + 30 °C	$P_c$	9.59	kW		T <sub>j</sub> = + 30 °C	EER	4.43	-
T <sub>j</sub> = + 25 °C	$P_c$	6.27	kW		T <sub>j</sub> = + 25 °C	EER	6.91	-
T <sub>j</sub> = + 20 °C	$P_c$	3.19	kW		T <sub>j</sub> = + 20 °C	EER	10.87	-
Average heating season indoor temperature 20 ° <i>T j</i>					Average season co			
Rated heating capacity	P <sub>rated,h</sub>	15.50	kW		Seasonal space heating energy efficiency	$\eta_{s,h}$	141.0	%
T <sub>j</sub> = -7 °C	$P_h$	10.45	kW		T <sub>j</sub> = -7 °C	СОР	2.55	-
T <sub>j</sub> = +2 °C	$P_h$	6.32	kW		T <sub>j</sub> = +2 °C	СОР	3.35	-
T <sub>j</sub> = +7 °C	$P_h$	4.11	kW		T <sub>j</sub> = +7 °C	СОР	4.73	-
T <sub>j</sub> = +12 °C	$P_h$	2.88	kW		T <sub>j</sub> = +12 °C	СОР	6.08	-
Tbiv	$P_h$	10.45	kW		Tbiv	СОР	2.55	-

Page 10 of 10

Report NO.: *NTRE20170425* 



(EU) 2016/2281 and EN 14511 & EN 14825						
Clause	Requirement - Test	Result - Remark	Verdict			

ToL	$P_h$	9.92	kW		ToL	СОР	2.51	-
T j = - 15 °C (if T OL < - 20 °C)	Pth	-	kW		T j = -15 °C (if T OL < -20 °C)	СОР	-	-
Bivalent temperature	Tbiv	-7	°C		Operation limit temperature	ToL	-10	°C
Degradation co- efficient for air conditioners	C <sub>dc</sub>	0.25	-					
	Power co	nsumptio	n in mod	es o	ther than 'active mo	ode'		
Off mode	P <sub>OFF</sub>	0.002	kW		Crankcase heater mode	P <sub>CK</sub>	0	kW
Standby mode	P <sub>SB</sub>	0.002	kW		Back-up heating capacity	elbu		KW
Thermostat-off mode(cooling/heating)	P <sub>TO</sub>	0.013/0 .014	kW		Type of energy input		-	
			Other	iten	ns			
Capacity control		variable			air flow rate, outdoor measured(cooling	5900	m <sup>a</sup>	³/h
Sound power level, indoor/outdoor measured(cooling)	L <sub>WA</sub>	L <sub>WA</sub> 67.9/69.9			air flow rate, outdoor measured(heating )	5900	m <sup>3</sup>	³/h
Sound power level, indoor/outdoor measured(heating)	L <sub>WA</sub> 67.9/7		.1 dB		GWP of the refrigerant	675	_	O <sub>2 eq</sub> years)
Contact details for obtaining more information on the setting of the unit  Jinji West Road, Qianshan, Zhuhai, Guangdong 519070, P.R.China								

Email: greerzsykt@cn.gree.com

(\*) If Cdc is not determined by measurement then the default degradation coefficient air conditioners shall be 0,25.

Where information relates to multi-split air conditioners, the test result and performance data may be obtained on the basis of the performance of the outdoor unit, with a combination of indoor unit(s) recommended by the manufacturer or importer.